RegulusTOP PUMP STATIONS FOR HEATING SYSTEMS



CSE MIX FIX W Pump Station with electronic-controlled mixing

Pump station intended to control the temperature of return water to boiler or output temperature of heating circuits mixed to a constant temperature that can be adjusted directly on the mixing valve actuator, 0-99°C. A version designed for the right-hand pipe, possible to convert to a left-hand pipe version.

Technical Data

FLUID WORKING TEMPERATURE

MIXING VALVE ACTUATOR


POWER SUPPLY

5 - 95 °C control to constant temperature, 120 s, 6 Nm 230 V, 50 Hz

Components

- Wilo circulation pump with power cable w. connector
- · Mixing valve
- · Mixing valve actuator, electronic-controlled
- 2 Pt 1000 sensors
- · Neat insulation for reduced heat loss

Dimensions



Models

	CSE MIX FIX W 1M	CSE MIX FIX W 5/4M	CSE MIX FIX W 1F	CSE MIX FIX W 5/4F
Connections	1" (2x M, 1x F)*	5/4" (2x M, 1x F)*	1" (3x F)	5/4" (3x F)
Pump Wilo Yonos Para	RS25/6	RS25/7,5	RS25/6	RS25/7,5
Pump speed control	manual	manual	manual	manual
Max. head	6.2 m	7.6 m	6.2 m	7.6 m
K_{vs} of the mixing valve	6.3 m³/h	12 m³/h	10 m³/h	16 m³/h
Code	16083	16846	16220	16216

^{*} the inner thread is located at the outlet end of the pump

Accessories

	Name	Application	Code
***	CSE/HV Kit	2 threaded fittings, 1 T-piece, 1 ball valve for an easy connection to Regulus heating circuit manifolds	16922
	T-piece, 1" M/Fu/M, 90 mm	to connect a return line to a mixing valve	16660
	T-piece, 1" M/Fu/M, 125 mm	for an easy connection to Regulus heating circuit manifolds	16659
2	1" Fu/F Fittings	union nut x F thread	15694