DATA SHEET

RGMAT E R8 1F KK Pump Station

Main Features	
Description	This load unit is intended for use in systems with solid-fuel boilers and fireplaces. The load valve integrated in the load unit ensures keeping the min. inlet temperature to the boiler (fire) above the flue condensing temperature, thus preventing a low-temperature corrosion of the boiler combustion chamber. The load unit thus contributes to a significant limitation of tarring and fouling of the boiler, to an increased efficiency in fuel combustion and to extending the service life of the boiler. The load unit is equipped with a set of three G 6/4" ball valves with union nuts, making repairs/disassembling easier, without the need to drain the system. The Load Unit consists of: • RPA 25-8 Pump, • TSV5 BMF 6/4M x 5/4F Load Valve w. outer threads and automatic bypass balancing, • three G 6/4" ball valves with union nut, • thermometer, • insulation.
Working fluid	Water; water–glycol mixture (max. 1:1). pH range 6.5–8.5. We recommend placing a filter with a mesh size of max. 0.6 mm upstream of the pump – e.g. Magnet FilterBall – see the Catalogue for codes.
Installation	On return piping, min. dist. of the pipe axis from a wall is 100 mm.

Codes	Boiler output
21459 – for valve opening temperature 55 °C	max. 53 kW
21460 – for valve opening temperature 65 °C	max. 38 kW

Technical Data	
Fluid working temperature	5–95 °C
Max. working pressure	6 bar
Min. working pressure	0.5 bar
Ambient temperature	5–40 °C
Max. relative humidity	80 %, non condensing
Control Range of the Load Valve	opening temperature +5 °C
Load valve Kvs (A ►AB direction)	7.3 m³/h
Load valve Kvs (B ►AB direction)	7.3 m³/h
Pump motor protection	integrated
Overall dimensions	350 x 185 x 155 mm
Total weight	4.2 kg
Connections	3 x G 1" F

Electric Data	
Power supply	230 V, 50 Hz
Max. power input	65 W
Max. current	0.65 A
IP rating	IP44
Power cable length	3 m

Materials	
Insulation	EPP RG 60 g/l
Load Valve and fittings	brass
Thermostatic element and plug seal	EPDM
Load Valve cone seal	NBR

REGULUS spol. s r. o. Czech Republic
Do Koutů 1897/3, 143 00 Praha 4
Tel.: +420 241 765 191
Fax: +420 241 763 976
E-mail: sales@regulus.eu
Web: www.regulus.eu

DATA SHEET

RGMAT E R8 1F KK Pump Station

Valve pressure drop diagram



Pump performance curves

Constant speed



Variable pressure



Constant pressure



DATA SHEET

RGMAT E R8 1F KK Pump Station

Example of possible connection I



The diagram shows a typical connection of a solid fuel boiler, thermal store and heating circuit (with the recommended CSE MIX R8 pump station – not included in supply). If the boiler is used also for hot water heating, it is recommended to install a CSE OTS ZV R8 pump station (not included in supply).

Example of possible connection II



The diagram shows a typical connection of a solid fuel boiler, combination thermal store and a heating circuit (with the recommended CSE MIX R8 pump station – not included in supply).

R E G U L U S spol. s r. o. Czech Republic
Do Koutů 1897/3, 143 00 Praha 4
Tel.: +420 241 765 191
Fax: +420 241 763 976
E-mail: sales@regulus.eu
Web: www.regulus.eu