

DECLARATION OF CONFORMITY

Name and address of the Supplier Company:

REGULUS spol. s r.o.
Do Koutů 1897/3
CZ-143 00 Prague 4
Company ID No.: 453 17 020

Description of the product:

Ball valve with integrated strainer + magnet MAGNET FILTERBALL
Ball valve with integrated strainer FLOW FILTERBALL

Technical Standards:

ČSN 133060-1:1988; ČSN 133060-2:1978; ČSN 133060-3:1978; ČSN 133060-4:1992;
ČSN 137100:1963; ČSN EN 19:2016; ČSN EN 13443-2+A1:2008; ČSN EN 13828:2005;
ČSN EN ISO 9001:2016

List of the Technical Regulation:

The Government Regulation No. 163/2002 of the Coll
which stipulates technical requirements for the determined building product
Edict of Ministry of Health of the Czech Republic No. 409/2005 Coll., on hygienic requirements for
products coming into direct contact with water and for water treatment

Set of declared technical characteristics

Max. working pressure: 16 bar
Max. working temperature: - 20 °C to 100 °C
Magnetic induction: 3500-7000 Gs
Filter mesh size: 0,6 mm

Data on the Certification Body:

Engineering Test Institute
authorized body 202; notified body ES 1015
Hudcova 56b, CZ-621 00 Brno

Reference to the Certificate:

Product Certificate No. 227/C5/2024/0154 on the 17 May 2024
Certification Protocol No. 227-P5-24-0154 on the 17 May 2024

in Prague, May 17, 2024


Mgr. Milan Brezina REGULUS spol. s r.o.
quality manager Do Koutů 1897/3
143 00 Praha 4