

EU DECLARATION OF CONFORMITY

Name and address of the manufacturer:

REGULUS spol. s r.o.
Prague 4 - Modřany, Do Koutů 1897/3, CZ-143 00
Company ID No.: 453 17 020

Description of the product (product, type):

Pump RPA 25-8, G 6/4"

This declaration of conformity is issued under the sole responsibility of the manufacturer

Object of the declaration (product description, technical data):

High-efficiency wet-running ON/OFF circulation pump intended for circulation of fluids in heating systems; the pump is equipped with an anti-block motor w. integrated electronic performance control; LED operation indication for easy monitoring; selection from the following modes possible: constant speed I, II, III, PP mode for variable differential pressure or CZ for constant differential pressure.

Fluid working temperature: 5-110 °C

Ambient temperature: 5 to 40 °C

Max. working pressure: 10 bar

Weight: 130 mm - 1,75 kg / 180 mm - 1,86 kg

Power supply: 1~230 V, 50/60 Hz

Max. power consumption: 65 W

Max. current: 0,65 A

IP rating: IP 44

**The object of the declaration described above is in conformity with the relevant
Union harmonisation legislation:**

Directive 2014/35/EU - electrical equipment designed for use within certain voltage limits (LVD)

Directive 2014/30/EU - electromagnetic compatibility (EMC)

Directive 2006/42/EU - machinery directive (MD)

References to the relevant harmonised standards used:

EN 60335-1:2012/A15:2021; EN 60335-2-51:2023; EN 62233:2008;

EN IEC 55014-1:2021; EN IEC 55014-2:2021;

EN IEC 61000-3-2:2019/A1:2021; EN 61000-3-3:2013/A2:2021

Data on the person involved in the conformity assessment:

TÜV SÜD Product Service GmbH
Ridlerstraße 65
80339 Munich
Germany

Reference to certificates and test reports:

Test Report MD and LVD No. 874012301112-01 on the 01.12.2023
Attestation of Conformity MD and LVD No. M8A 101057 0127 Rev. 01 on the 18.12.2023
Attestation of Conformity EMC No. E8A 101057 0126 Rev. 01 on the 07.12.2023

Place and date of issue, name, function, signature:

in Prague, November 1, 2024



Mgr. Milan Březina
quality manager

